This Article Information Sheet (AIS) provides relevant battery information to retailers, consumers, OEMs and others users requesting a GHS-compliant SDS. Articles, such as batteries, are exempt from GHS SDS classification criteria. The GHS criteria is not designed or intended to be used to classify the physical, health and environmental hazards of an article. Branded consumer batteries are defined as electro-technical devices. The design, safety, manufacture, and qualification of branded consumer batteries follow ANSI and IEC battery standards. This document is based on principles set forth in the following hazard communication approaches: ANSI Z-400.1, GHS, JAMP AIS, and IEC 62474.

1. Document Information	
Document Name	Duracell Nickel Metal Hydride (NiMH) Rechargeable Batteries
Document ID	AIS-NiMH
Issue Date	1-Dec-15
Version	2
Preparer	Global Product Stewardship
Last Revision	1/7/2016
Information Contact	benoit.sa@duracell.com
2. Company Information	
Name & Address	Duracell Global Business Unit, 14 Research Drive, Bethel, CT USA 06801
Telephone	(203) 796- 4000
Website	www.duracell. com
Consumer Relations	North America: 1-800-551-2355 (9:00 AM - 5:00 PM EST)
3. Article Information	
Description	Duracell branded consumer nickel metal hydride rechargeable battery
Product Category	Electro-technical device
Use	Portable power source for electronic devices
Global sub-brands (Retail)	RECHARGEABLE
Sizes	AA, AAA, C, D & 9V
IEC Designations	HR6, HR03, HR9V, HR14, HR20
(IEC 62133)	
Principles of Operation	A battery powers a device by converting stored chemical energy into electrical energy.
Representative Product Image	DURACELL RECHARGEABLE 50% LONGER LASTING LONG PLUS DURABLE LONG PLUS DURABLE LONG PLUS DURABLE LONG LONG PLUS DURABLE L

4. Article Construction

4. Alticic construction	
Applicable Battery Industry Standards	ANSI C18.2M Part 1, ANSI C18.2M Part 2, ANSI C18.4, IEC 61951-2, IEC 62133
Electro-technical System	Nickel Metal Hydride
Anode (Electrode - Negative)	Metal hydride
Cathode (Electrode - Positive)	Nickel oxides
Electrolyte	Alkali Metal Hydroxide (aqueous potassium hydroxide - CAS # 1310-58-3)
Materials of Construction - Can	Nickel Plated Steel
Declarable Substances (IEC 62474 Criteria 1) List Updated 7/15/2015	None - See Section 10b of this document (page 4)
Mercury Free Battery (ANSI C18.4M <5ppm)	Yes

AIS-NiMH 1 of 4

(ANSI C18.1M Part 2; IEC 60086-5) 5. Health & Safety Ingestion/Small Parts Warning Required for Battery Size AAA: Keep away from children. If swallowed, consult a physician immediately. Normal Conditions of Use Exposure to contents inside the sealed battery will not occur unless the battery leaks, is exposed to high temperatures, or is mechanically abused. Note to Physician A damaged battery will release concentrated and caustic potassium hydroxide. Do not induce vomiting. Seek medical attention immediately. USA CALLS ONLY - CALL 24-HOUR NATIONAL BATTERY INGESTION HOTLINE; (202) 625-3333 - COLLECT. First Aid - Is will water for at least 15 minutes. Seek medical care if irritation persists. First Aid - Inhalation Remove contaminated clothing. Wash skin with soap and water. Seek medical care if irritation persists. Remove to fresh air. Battery Safety Standards & Testing Duracell batteries meet the requirements of ANSI C18. 2M Part 2; IEC 61951-2, and IEC 62133. These standards specify tests and requirements for alkaline batteries to ensure safe operation under normal use and reasonably foreseeable misuse. The test regimes assess three conditions of safety. These are: 1-intended use simulation: Partial use, vibration, thermal shock, and mechanical shock 2-Reasonably foreseeable misuse; Incorrect installation, external short-circuit, free fall (user-drop), over-discharge, and crush 3-Design consideration: Thermal abuse, mold stress Precautionary Statements CAUTION: Batteries may explode or leak, and cause burn injury, if recharged, disposed of in fire, mixed with a different battery type, inserted backwards or disassembled. Replace all used batteries at the same time. Do not carry batteries loose in your pocket or purse. Do not remove the battery label. Keep small batteries (ie., AAA) away from children. If swallowed, consult a physician at once. 6. Fire Hazard Batteries may rupture or leak if involved in a fire. Extinguishing Media Large quantities of batteries involved in a fire will rupture a		
Ingestion/Small Parts Warning	Small Cell or Battery (ANSI C18.1M Part 2; IEC 60086-5)	
Ingestion/Small Parts Warning Required for Battery Size AAA: Keep away from children. If swallowed, consult a physician immediately. Normal Conditions of Use Exposure to contents inside the sealed battery will not occur unless the battery leaks, is exposed to high temperatures, or is mechanically abused. A damaged battery will release concentrated and caustic potassium hydroxide. Do not induce vomiting. Seek medical attention immediately. USA CALLS ONLY - CALL 24-HOUR NATIONAL BATTERY INGESTION HOTLINE: (202) 625-3333 - COLLECT. First Aid - Eye Contact First Aid - Skin Contact First Aid - Inhalation Remove contaminated clothing. Wash skin with soap and water. Seek medical care if irritation persists. First Aid - Inhalation Battery Safety Standards & Testing Battery Safety Standards & Testing Callas. These standards specify tests and requirements for alkaline batteries to ensure safe operation under normal use and reasonably foreseeable misuse. The test regimes assess three conditions of safety. These are: 1-Intended use simulation: Partial use, vibration, thermal shock, and mechanical shock 2-Reasonably foreseeable misuse; incorrect installation, external short-circuit, free fall (user-drop), over-discharge, and crush 3-Design consideration; Thermal abuse, mold stress Precautionary Statements CAUTION: Batteries may explode or leak, and cause burn injury, if recharged, disposed of in fire, mixed with a different battery type, inserted backwards or disassembled. Replace all used batteries at the same time. Do not carry batteries loose in your pocket or purse. Do not remove the battery label. Keep small batteries (i.e., AAA) away from children. If swallowed, consult a physician at once. 6. Fire Hazard Batteries may rupture or leak if involved in a fire. Extinguishing Media Large quantities of batteries involved in a fire. Large quantities of batteries in a fire will rupture and release caustic potassium hydroxide. Firefighter	-	
Note to Physician A damaged battery will release concentrated and caustic potassium hydroxide. A damaged battery will release concentrated and caustic potassium hydroxide. Do not induce vomitting. Seek medical attention immediately. USA CALLS ONLY - CALL 24-HOUR NATIONAL BATTERY INGESTION HOTLINE: (202) 625-3333 - COLLECT. First Aid - Skin Contact Flush with water for at least 15 minutes. Seek medical care if irritation persists. Remove contaminated clothing. Wash skin with soap and water. Seek medical care if irritation persists. Remove to fresh air. Battery Safety Standards & Testing Battery Safety Standards & Testing Buracell batteries meet the requirements of ANSI C18. 2M Part 2; IEC 61951-2, and IEC 62133. These standards specify tests and requirements for alkaline batteries to ensure safe operation under normal use and reasonably foreseeable misuse. The test regimes assess three conditions of safety. These are: 1-intended use simulation; Partial use, vibration, thermal shock, and mechanical shock 2-Reasonably foreseeable misuse; incorrect installation, external short-circuit, free fall (user-drop), over-discharge, and crush 3-Design consideration: Thermal abuse, mold stress Precautionary Statements CAUTION: Batteries may explode or leak, and cause burn injury, if recharged, disposed of in fire, mixed with a different battery type, inserted backwards or disassembled. Replace all used batteries at the same time. Do not carry batteries loose in your pocket or purse. Do not remove the battery label. Keep small batteries lose in your pocket or purse. Do not remove the battery type, inserted backwards or disassembled. Replace all used batteries may rupture or leak if involved in a fire. Extinguishing Media Fires Involving Large Quantities of Batteries may rupture or leak if involved in a fire expression of the surrounding area. Large quantities of batteries in accordance with equipment instructions. Storage Precautions Avoid mechanical and electrical abuse. Do not short circuit or install incorrectly	Ingestion/Small Parts Warning	
Do not induce vomiting. Seek medical attention immediately. USA CALLS ONLY - CALL 24-HOUR NATIONAL BATTERY INGESTION HOTLINE: (202) 625-3333 - COLLECT. First Aid - Eye Contact Flush with water for at least 15 minutes. Seek medical care if irritation persists. Remove contaminated clothing. Wash skin with soap and water. Seek medical care if irritation persists. Remove to fresh air. Battery Safety Standards & Testing Duracell batteries meet the requirements of ANSI C18. 2M Part 2; IEC 61951-2, and IEC 62133. These standards specify tests and requirements for alkaline batteries to ensure safe operation under normal use and reasonably foreseeable misuse. The test regimes assess three conditions of safety. These are: 1-Intended use simulation: Partial use, vibration, thermal shock, and mechanical shock 2-Reasonably foreseeable misuse; Incorrect installation, external short-circuit, free fall (user-drop), over-discharge, and crush 3-Design consideration: Thermal abuse, mold stress Precautionary Statements CAUTION: Batteries may explode or leak, and cause burn injury, if recharged, disposed of in fire, mixed with a different battery type, inserted backwards or disassembled. Replace all used batteries at the same time. Do not carry batteries loose in your pocket or purse. Do not remove the battery label. Keep small batteries loose in your pocket or purse. Do not remove the battery label. Keep small batteries loose in your pocket or purse. Do not remove the battery label. Seep small batteries loose in your pocket or purse. Do not remove the battery label. Seep small batteries loose in your pocket or purse. Do not remove the battery label. Seep small batteries loose in your pocket or purse. Do not remove the battery label. Seep small batteries loose in your pocket or purse. Do not remove the battery label. Seep small batteries of the surrounding area. Large quantities of batteries may rupture or leak if involved in a fire. Extinguishing Media Use any extinguishing media appropriate for the surroundi	Normal Conditions of Use	
First Aid - Eye Contact First Aid - Eye Contact First Aid - Skin Contact First Aid - Inhalation Battery Safety Standards & Testing Batteries Safety Standards Safety Standards Safety Safe	Note to Physician	A damaged battery will release concentrated and caustic potassium hydroxide.
Remove contaminated clothing. Wash skin with soap and water. Seek medical care if irritation persists. First Aid - Inhalation Battery Safety Standards & Testing Duracell batteries meet the requirements of ANSI C18. 2M Part 2; IEC 61951-2, and IEC 62133. These standards specify tests and requirements for alkaline batteries to ensure safe operation under normal use and reasonably foreseeable misuse. The test regimes assess three conditions of safety. These are: 1-intended use simulation: Partial use, vibration, thermal shock, and mechanical shock 2-Reasonably foreseeable misuse. The test regimes assess three conditions of safety. These are: 1-intended use simulation: Partial use, vibration, thermal short-circuit, free fall (user-drop), over-discharge, and crush 3-Design consideration: Thermal abuse, mold stress CAUTION: Batteries may explode or leak, and cause burn injury, if recharged, disposed of in fire, mixed with a different battery type, inserted backwards or disassembled. Replace all used batteries at the same time. Do not carry batteries loose in your pocket or purse. Do not remove the battery label. Keep small batteries (i.e., AAA) away from children. If swallowed, consult a physician at once. 6. Fire Hazard Batteries may rupture or leak if involved in a fire. Extinguishing Media Use any extinguishing media appropriate for the surrounding area. Large quantities of batteries involved in a fire will rupture and release caustic potassium hydroxide. Firefighters should wear self-contained breathing apparatus and protective clothing. 7. Handling & Storage Handling Precautions Avoid mechanical and electrical abuse. Do not short circuit or install incorrectly. Batteries may rupture or vent if disassembled, crushed, recharged or exposed to high temperatures. Install batteries in accordance with equipment instructions. Storage Precautions Storage Quantities of Loose Batteries in user. In the present of the surrounding and protective clothing or ruptured batteries and allow vapors to dissipate. Elimi	First Aid - If swallowed	
First Aid - Inhalation Remove to fresh air. Battery Safety Standards & Testing Duracell batteries meet the requirements of ANSI C18. 2M Part 2; IEC 61951-2, and IEC 62133. These standards specify tests and requirements for alkaline batteries to ensure safe operation under normal use and reasonably foreseeable misuse. The test regimes assess three conditions of safety. These are: 1-Intended use simulation: Partial use, vibration, thermal shock, and mechanical shock 2-Reasonably foreseeable misuse: Incorrect installation, external short-circuit, free fall (user-drop), over-discharge, and crush 3-Design consideration: Thermal abuse, mold stress Precautionary Statements CAUTION: Batteries may explode or leak, and cause burn injury, if recharged, disposed of in fire, mixed with a different battery type, inserted backwards or disassembled. Replace all used batteries at the same time. Do not carry batteries loose in your pocket or purse. Do not remove the battery label. Keep small batteries (i.e., AAA) away from children. If swallowed, consult a physician at once. 6. Fire Hazard & Firefighting Fire Hazard Batteries may rupture or leak if involved in a fire. Extinguishing Media Use any extinguishing media appropriate for the surrounding area. Large quantities of batteries involved in a fire will rupture and release caustic potassium hydroxide. Firefighters should wear self-contained breathing apparatus and protective clothing. 7. Handling & Storage Handling Precautions Avoid mechanical and electrical abuse. Do not short circuit or install incorrectly. Batteries may rupture or vent if disassembled, crushed, recharged or exposed to high temperatures. Install batteries in a coordance with equipment instructions. Storage Precautions Storage Quantities of Loose Batteries (unpackaged) Notify spill personnel of large spills. Irritating and flammable vapors may be released from leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all ignition sources. Evacuate area and allow vapors to	First Aid - Eye Contact	Flush with water for at least 15 minutes. Seek medical care if irritation persists.
Battery Safety Standards & Testing Duracell batteries meet the requirements of ANSI C18. 2M Part 2; IEC 61951-2, and IEC 62133. These standards specify tests and requirements for alkaline batteries to ensure safe operation under normal use and reasonably foreseeable misuse. The test regimes assess three conditions of safety. These are: 1-Intended use simulation: Partial use, vibration, thermal shock, and mechanical shock 2-Reasonably foreseeable misuse: Incorrect installation, external short-circuit, free fall (user-drop), over-discharge, and crush 3-Design consideration: Thermal abuse, mold stress CAUTION: Batteries may explode or leak, and cause burn injury, if recharged, disposed of in fire, mixed with a different battery type, inserted backwards or disassembled. Replace all used batteries at the same time. Do not carry batteries loose in your pocket or purse. Do not remove the battery label. Keep small batteries (i.e., AAA) away from children. If swallowed, consult a physician at once. 6. Fire Hazard & Firefighting Fire Hazard Setringuishing Media Use any extinguishing media appropriate for the surrounding area. Large quantities of batteries involved in a fire. Extinguishing Media Use any extinguishing media appropriate for the surrounding area. Large quantities of batteries involved in a fire will rupture and release caustic potassium hydroxide. Firefighters should wear self-contained breathing apparatus and protective clothing. 7. Handling & Storage Handling Precautions Avoid mechanical and electrical abuse. Do not short circuit or install incorrectly. Batteries may rupture or vent if disassembled, crushed, recharged or exposed to high temperatures. Install batteries in accordance with equipment instructions. Store batteries in a dry place at normal room temperature. Refrigeration does not make them last longer. Notify spill personnel of large spills. Irritating and flammable vapors may be released from leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all igni	First Aid - Skin Contact	
62133. These standards specify tests and requirements for alkaline batteries to ensure safe operation under normal use and reasonably foreseeable misuse. The test regimes assess three conditions of safety. These are: 1-Intended use simulation: Partial use, vibration, thermal shock, and mechanical shock 2-Reasonably foreseeable misuse: Incorrect installation, external short-circuit, free fall (user-drop), over-discharge, and crush 3-Design consideration: Thermal abuse, mold stress CAUTION: Batteries may explode or leak, and cause burn injury, if recharged, disposed of in fire, mixed with a different battery type, inserted backwards or disassembled. Replace all used batteries at the same time. Do not carry batteries loose in your pocket or purse. Do not remove the battery label. Keep small batteries (i.e., AAA) away from children. If swallowed, consult a physician at once. 6. Fire Hazard Batteries may rupture or leak if involved in a fire. Extinguishing Media Use any extinguishing media appropriate for the surrounding area. Large quantities of batteries involved in a fire will rupture and release caustic potassium hydroxide. Firefighters should wear self-contained breathing apparatus and protective clothing. 7. Handling & Storage Handling Precautions Avoid mechanical and electrical abuse. Do not short circuit or install incorrectly. Batteries may rupture or vent if disassembled, crushed, recharged or exposed to high temperatures. Install batteries in accordance with equipment instructions. Storage Precautions Storage Quantities of Loose Batteries (unpackaged) Notify spill personnel of large spills. Irritating and flammable vapors may be released from leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for disposal.	First Aid - Inhalation	Remove to fresh air.
in fire, mixed with a different battery type, inserted backwards or disassembled. Replace all used batteries at the same time. Do not carry batteries loose in your pocket or purse. Do not remove the battery label. Keep small batteries (i.e., AAA) away from children. If swallowed, consult a physician at once. 6. Fire Hazard Extinguishing Fire Hazard Batteries may rupture or leak if involved in a fire. Extinguishing Media Use any extinguishing media appropriate for the surrounding area. Fires Involving Large Quantities of Batteries involved in a fire will rupture and release caustic potassium hydroxide. Firefighters should wear self-contained breathing apparatus and protective clothing. 7. Handling & Storage Handling Precautions Avoid mechanical and electrical abuse. Do not short circuit or install incorrectly. Batteries may rupture or vent if disassembled, crushed, recharged or exposed to high temperatures. Install batteries in accordance with equipment instructions. Storage Precautions Store batteries in a dry place at normal room temperature. Refrigeration does not make them last longer. Spills of Large Quantities of Loose Batteries (unpackaged) Notify spill personnel of large spills. Irritating and flammable vapors may be released from leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for disposal. Remove any spilled liquid with absorbent material and contain for disposal.	Battery Safety Standards & Testing	62133. These standards specify tests and requirements for alkaline batteries to ensure safe operation under normal use and reasonably foreseeable misuse. The test regimes assess three conditions of safety. These are: 1-Intended use simulation: Partial use, vibration, thermal shock, and mechanical shock 2-Reasonably foreseeable misuse: Incorrect installation, external short-circuit, free fall (user-drop), over-discharge, and crush
Fire Hazard Extinguishing Media Use any extinguishing media appropriate for the surrounding area. Large quantities of batteries involved in a fire will rupture and release caustic potassium hydroxide. Firefighters should wear self-contained breathing apparatus and protective clothing. 7. Handling & Storage Handling Precautions Avoid mechanical and electrical abuse. Do not short circuit or install incorrectly. Batteries may rupture or vent if disassembled, crushed, recharged or exposed to high temperatures. Install batteries in accordance with equipment instructions. Storage Precautions Store batteries in a dry place at normal room temperature. Refrigeration does not make them last longer. Notify spill personnel of large spills. Irritating and flammable vapors may be released from leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for disposal. Remove any spilled liquid with absorbent material and contain for disposal.	Precautionary Statements	in fire, mixed with a different battery type, inserted backwards or disassembled. Replace all used batteries at the same time. Do not carry batteries loose in your pocket or purse. Do not remove the battery label. Keep small batteries (i.e., AAA) away from children. If
Extinguishing Media Use any extinguishing media appropriate for the surrounding area. Large quantities of batteries involved in a fire will rupture and release caustic potassium hydroxide. Firefighters should wear self-contained breathing apparatus and protective clothing. 7. Handling & Storage Handling Precautions Avoid mechanical and electrical abuse. Do not short circuit or install incorrectly. Batteries may rupture or vent if disassembled, crushed, recharged or exposed to high temperatures. Install batteries in accordance with equipment instructions. Storage Precautions Store batteries in a dry place at normal room temperature. Refrigeration does not make them last longer. Spills of Large Quantities of Loose Batteries (unpackaged) Notify spill personnel of large spills. Irritating and flammable vapors may be released from leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for disposal. Remove any spilled liquid with absorbent material and contain for disposal.	6. Fire Hazard & Firefighting	
Large quantities of batteries involved in a fire will rupture and release caustic potassium hydroxide. Firefighters should wear self-contained breathing apparatus and protective clothing. 7. Handling & Storage Handling Precautions Avoid mechanical and electrical abuse. Do not short circuit or install incorrectly. Batteries may rupture or vent if disassembled, crushed, recharged or exposed to high temperatures. Install batteries in accordance with equipment instructions. Storage Precautions Store batteries in a dry place at normal room temperature. Refrigeration does not make them last longer. Spills of Large Quantities of Loose Batteries (unpackaged) Notify spill personnel of large spills. Irritating and flammable vapors may be released from leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for disposal. Remove any spilled liquid with absorbent material and contain for disposal.	Fire Hazard	Batteries may rupture or leak if involved in a fire.
hydroxide. Firefighters should wear self-contained breathing apparatus and protective clothing. 7. Handling & Storage Handling Precautions Avoid mechanical and electrical abuse. Do not short circuit or install incorrectly. Batteries may rupture or vent if disassembled, crushed, recharged or exposed to high temperatures. Install batteries in accordance with equipment instructions. Storage Precautions Store batteries in a dry place at normal room temperature. Refrigeration does not make them last longer. Notify spill personnel of large spills. Irritating and flammable vapors may be released from leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for disposal. Remove any spilled liquid with absorbent material and contain for disposal.	Extinguishing Media	Use any extinguishing media appropriate for the surrounding area.
Avoid mechanical and electrical abuse. Do not short circuit or install incorrectly. Batteries may rupture or vent if disassembled, crushed, recharged or exposed to high temperatures. Install batteries in accordance with equipment instructions. Storage Precautions Store batteries in a dry place at normal room temperature. Refrigeration does not make them last longer. Spills of Large Quantities of Loose Batteries (unpackaged) Notify spill personnel of large spills. Irritating and flammable vapors may be released from leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for disposal. Remove any spilled liquid with absorbent material and contain for disposal.	Fires Involving Large Quantities of Batteries	hydroxide. Firefighters should wear self-contained breathing apparatus and protective
may rupture or vent if disassembled, crushed, recharged or exposed to high temperatures. Install batteries in accordance with equipment instructions. Storage Precautions Store batteries in a dry place at normal room temperature. Refrigeration does not make them last longer. Spills of Large Quantities of Loose Batteries (unpackaged) Notify spill personnel of large spills. Irritating and flammable vapors may be released from leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for disposal. Remove any spilled liquid with absorbent material and contain for disposal.	7. Handling & Storage	
them last longer. Spills of Large Quantities of Loose Batteries (unpackaged) Notify spill personnel of large spills. Irritating and flammable vapors may be released from leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for disposal. Remove any spilled liquid with absorbent material and contain for disposal.	Handling Precautions	may rupture or vent if disassembled, crushed, recharged or exposed to high
leaking or ruptured batteries. Spread batteries apart to stop shorting. Eliminate all ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for disposal. Remove any spilled liquid with absorbent material and contain for disposal.	Storage Precautions	
ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for disposal. Remove any spilled liquid with absorbent material and contain for disposal.	Spills of Large Quantities of Loose	Notify spill personnel of large spills. Irritating and flammable vapors may be released from
8. Disposal Considerations (GHS Section 13)	Batteries (unpackaged)	ignition sources. Evacuate area and allow vapors to dissipate. Clean-up personnel should wear appropriate PPE to avoid eye and skin contact and inhalation of vapors or fumes. Increase ventilation. Carefully collect batteries and place in appropriate container for
	8. Disposal Considerations (GHS Sections)	ion 13)

AIS-NiMH 2 of 4

Collection & Proper Disposal	Dispose of used (or excess) batteries in compliance with federal, state/provincial and local regulations. Do not accumulate large quantities of used batteries for disposal as accumulations could cause batteries to short-circuit. Do not incinerate. In countries, such as Canada and the EU, where there are regulations for the collection and recycling of batteries, consumers should dispose of their used batteries into the collection network at municipal depots and retailers. They should not dispose of batteries with household trash.
USA EPA RCRA (40 CFR 261)	Nickel metal hydride rechargeable batteries are considered RCRA Universal Waste as long as they are recycled. In some states (California, New York, Minnesota, and Maine) Nickel metal hydride batteries must be recycled by state law.
California Universal Waste Rule (Cal. Code Regs. Title 22, Div. 4.5, Ch. 23)	California prohibits disposal of batteries as trash (including household trash).
9. Transport Information (GHS Section	n 14)
Regulatory Status	Nickel metal hydride (NiMH) batteries are not defined as dangerous goods under IATA, ICAO, and DOT. For air and ground transportation these batteries are not subject to dangerous goods regulations. <u>NIMH batteries are defined as dangerous goods under IMDG code for sea transportation.</u>
UN Identification Number/ Shipping Name	UN3496 - Batteries, Nickel Metal Hydride
Special Provision (SP) Conformance	Special regulatory provisions require batteries to be packaged in a manner that prevents the generation of a dangerous quantity of heat and short circuits. Shippers can prepare batteries by taping the terminals, individually packaging batteries, or otherwise segregating the batteries to prevent risk of creating a short circuit. Batteries shipped in original unopened Duracell packaging is compliant.
Internation Maritme Dangerous Goods (IMDG)	CODE: UN-3496, SP-117 & SP-963
US DOT SP	49 CFR 172.102 Special Provisions 130 and 340
Air Transport (IATA/ICAO) SP	Special Provision A123 (IATA 57th Edition - 2016). NOTE: The words "NOT RESTRICTED" and "SPECIAL PROVISION A123" must be included on the description of the substance on the Air Waybill, when air way-bill is issued.
Passenger Air Travel	No restrictions
Emergency Transportation Hotline	CHEMTREC 24-Hour Emergency Response Hotline Within the United States call +703-527-3887 Outside the United States, call +1 703-527-3887 (Collect)
10. Regulatory Information (GHS Sect	ion 15)
10a. Battery Requirements USA EPA Mercury Containing & Rechargeable Battery Management Act of 1996	During the manufacturing process, no mercury is added.
EU Battery Directive 2006/66/EC & amendment 2013/56/EU	Compliant with marking and substance restrictions for mercury (<0.0005%); cadmium (<0.0020%)I and lead (<0.0040%). Global labels are marked with the special collection symbol and the EU qualifier in accordance with EU Battery Directive 2006/66/EC, Article 11, Paragraph 1 on batteries and accumulators and waste batteries and accumulators (Annex II).
10b. General Requirements	
USA CPSIA 2008 (PL. 11900314)	Exempt
USA CPSC FHSA (16 CFR 1500)	Consumer batteries are not listed as a hazardous product.
USA EPA TSCA Section 13 (40 CFR 707.20)	For customs clearance purpose, batteries are defined as an "Article".

AIS-NiMH 3 of 4

USA EPA RCRA (40 CFR 261)	Nickel metal hydride rechargeable batteries are considered RCRA Universal Waste as long
,	as they are recycled. In some states (California, New York, Minnesota, and Maine) Nickel
	metal hydride batteries must be recycled by state law.
California Prop 65	No warning required per 3rd party assessment.
CANADA Products Containing	Mercury free
Mercury Regulations SOR/20140254	
EU REACH SVHC's (168	No listed substances are present (>0.01% w/w)
Substances/Candidate List December	
EU REACH Annex XVII	The use of nickel in batteries does not meet the conditions of restriction described for
	Annex XVII Item #27 - Nickel. The use restriction applies for articles intended to come
	into direct and prolonged contact with the skin, specifically pierced earring posts and
ELL DE A CIL A vicile 24	other types of jewelry.
EU REACH Article 31	SDS is not required consumer alkaline batteries.
10c. Regulatory Definitions - Articles	
USA OSHA	29 CFR 1910.1200(b)(6)(v)
USA TSCA	40 CFR 704.3; 710.2(3)(c); and [19 CFR 12.1209a)]
EU REACH	Title 1 - Chapter 2 - Article 3(3)
GHS	Section 1.3.2.1
11. Other Information	
	es (consulted in developing this document):
Globally Harmonized System (GHS)	GHS SDS requirements and classification criteria do not apply to articles or products (such
	as batteries) that have a fixed shape, which are not intended to release a chemical. The
	article exemption is found in Section 1.3.2.1.1 of the GHS and reads: <i>The GHS applies to</i>
	pure substances and their dilute solutions and to mixtures. "Articles" as defined by the
	Hazard Communication Standard (29 CFR 1900.1200) of the OSHA of the USA, or by similar definition, are outside the scope of the system."
	Similar definition, are outside the scope of the system.
Joint Article Management Promotion	JAMP is a Japanese Industry Association who developed the concept of an Article
Consortium JAMP	Information Sheet as a supply chain tool to share and communicate chemical information
	in articles. The AIS authoring process is based on "declarable" substances to meet global
	regulatory requirements as well as substances to be reported by GADSL, JIG, etc.
150 C2474 54 4 0 D 2042 Marketick	As interesting the standard that are sinteresting to the Adams 2002
IEC 62474 Ed. 1.0 B:2012 Material	An international standard that came into effect in March 2012 concerning declaration for
Declaration for Products of and for the Electro-technical Industry	electrical and electronic products. IEC 6274 replaces the defunct Joint Industry Guide – Material Declaration for Electro-technical Products (JIG-101-Ed 4.1 (May 21, 2012)
the Electro-technical industry	Material Declaration for Electro-technical Products (JiG-101-Ed 4.1 (May 21, 2012)
IEC 62474 Database - Publically	The general principle for a substance to be included in the database as a declarable
	substance is: 1) existing national laws or regulations in an IEC member country that are
Environmental Standardization for	relevant to Electro-technical products and that prohibit or restrict substances, or that
electrical and electronic products and	
systems.	IEC 62474 criteria results in identification of declarable substance.
ANSI Z 400.1/Z19.1 (2010)	2.1 Scope: Applies to preparation of SDSs for hazardous chemicals used under
	occupational conditions. Does not address how the standard may be applied to articles.
	It presents basic information on how to develop and write a SDS. Additional information
	is provided to help comply with state and federal environmental and safety laws and
	regulations. Elements of the standard may be acceptable for International use.
•	de a brief summary of our knowledge and guidance regarding the use of this material. The
information contains it bear to be a	
	piled from sources considered by Duracell to be dependable and is accurate to the best of the be an all-inclusive document on worldwide hazard communication regulations. This information

is offered in good faith. Each user of this material needs to evaluate the conditions of use and design the appropriate protective mechanisms to prevent employee exposures, property damage or release to the environment.

injury to the recipient or third persons or for any damage to any property resulting from misuse of the product.

AIS-NiMH 4 of 4